



DRAINAGE – CURB CUT

**NOTES:**

1. CURB SHALL BE REMOVED AND REPLACED A MINIMUM OF TWELVE (12") INCHES PAST DRAIN OPENING. CURB SHALL BE REMOVED TO NEAT LINES BY SAW-CUTTING (NO EXCEPTIONS). IN LIEU OF CUTTING THE CURB, A FOUR (4") INCH DIAMETER CORE DRILL OF HOLE THROUGH CURB IS ACCEPTABLE UPON REQUEST.
2. UNLESS OTHERWISE NOTED ON PLANS, CONCRETE SHALL BE CLASS A, 3500 PSI READY MIX TYPE CONFORMING TO ASTM SPECIFICATION C94 AND COMPOSED OF PORTLAND CEMENT, SAND, AND WASHED COURSE LIMESTONE AGGREGATE. AIR-ENTRAINMENT SHALL BE 5%, ( $\pm 2\%$ ).
3. PIPE THRU CURB SHALL BE A MAXIMUM OF FOUR (4") INCHES DIAMETER AND SHALL BE PVC (SCHEDULE 40). WHEN AN OPENING SIZE GREATER THAN A SINGLE FOUR (4") INCH DIAMETER PIPE IS REQUIRED, A SIDEWALK DRAIN MUST BE USED.
4. ALL THRU-THE-CURB DRAINS MUST BE PRE-APPROVED BY THE CITY OF GERMANTOWN ENGINEERING DEPARTMENT AND MUST BE INSPECTED PRIOR TO INSTALLATION & COMPLETION.



ENGINEERING DEPARTMENT

DRAINAGE – CURB CUT

DRAWN: MLC

DATE: 08.10.23

CHECKED: JDB

REVISED: \_\_\_\_\_

APPROVED: EWS

SCALE: NTS