



PLAN

No. 12 DRAINAGE INLET

**NOTES:**

1. SOLID BRICK CONSTRUCTION SHALL USE STANDARD CONCRETE BRICK. HEADER COURSE REQUIRED EVERY FIFTH (5th) COURSE.
2. ALL PRECAST STRUCTURES MUST BE APPROVED BY THE CITY OF GERMANTOWN ENGINEERING DEPARTMENT PRIOR TO INSTALLATION OF STRUCTURE.
3. UNLESS OTHERWISE NOTED ON PLANS, CONCRETE SHALL BE CLASS A, 3500 psi READY MIX TYPE CONFORMING TO ASTM SPECIFICATION C94 AND COMPOSED OF PORTLAND CEMENT, SAND, AND WASHED COURSE LIMESTONE AGGREGATE.
4. STEPS SHALL BE ADDED TO ALL STRUCTURES HAVING A DEPTH GREATER THAN THREE (3') FEET. STEPS TO BE SPACED ON 18" CENTERS AND MAY BE WROUGHT IRON OR CAST IRON.
5. CURB-IRON SHALL BE STANDARD TDOT No. 12 STYLE. REFER TO TDOT STANDARD DETAIL D-CB-12B FOR ANY REINFORCING STEEL INFORMATION, CATCH BASIN MINIMUM DEPTH TABLE, CUT-OUT HOLES FOR INLET/INLET PIPES, AND ANY OTHER GENERAL NOTES.



ENGINEERING DEPARTMENT

No. 12 DRAINAGE INLET

DRAWN: <u>MLC</u>	DATE: <u>07.10.23</u>
CHECKED: <u>JDB</u>	REVISED: _____
APPROVED: <u>EWS</u>	SCALE: <u>NTS</u>