



SANITARY SEWER MANHOLE

NOTES:

1. ALL SANITARY SEWER MANHOLES SHALL BE SUBJECTED TO NEGATIVE PRESSURE (VACUUM) TESTING IN ACCORDANCE WITH THE CITY OF GERMANTOWN STANDARD SPECIFICATIONS, SECTION 6.4.2 AND ASTM C1244.
2. THE WATER STOP AROUND PIPE SHALL BE A RESILIENT CONNECTOR AS MANUFACTURED BY KOR-N-SEAL. (OR EQUAL), CONFORMING TO THE CITY OF GERMANTOWN STANDARD SPECIFICATIONS, SECTION 6.2.16.
3. MANHOLE STEPS SHALL BE INSTALLED A MAXIMUM OF 16" (8" MINIMUM) FROM TOP AND BOTTOM OF MANHOLE. ALL OTHER STEPS SHALL BE STAGGERED LATERALLY 12" O.C. & UNIFORMLY SPACED AT 16" O.C. (8" MINIMUM) AND MAY BE WROUGHT IRON OR CAST IRON CONFORMING TO ASTM C478-13 (RUBBER or PLASTIC COATED).



ENGINEERING DEPARTMENT

SANITARY SEWER MANHOLE

DRAWN: MLC

DATE: 10.31.24

CHECKED: JJA

REVISED: _____

APPROVED: EWS

SCALE: NTS